



Jim Doyle, Governor
Mary P. Burke, Secretary

February 10, 2005

JAY R.SMITH MFG.
SMITH INDUSTRIES, INC.
BILLY SMITH

PO BOX 3237
MONTGOMERY AL 36109-0237

Re: Description: GREASE INTERCEPTOR (also see SEWAGE TANKS)
Manufacturer: JAY R.SMITH MFG.
Product Name: REMEDIATOR GREASE TREATMENT SYSTEM
Model Number(s): 8970-20 (20 gpm), 8970-35 (35 gpm), and 8970-50 (50 gpm)
Product File No: 20040653

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 82.34 (5)(a)2. based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of February 2010.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product must be installed and maintained in accordance with the manufacturer's instructions.
- Approval is issued for this product because the design of the product meets the intent of s. Comm 82.34 (5)(a)2., Wis. Adm. Code that requires exterior grease interceptors for systems that discharge to POWTS. The intent of the code is met since this product provides treatment of FOG that meets the performance requirements of code acceptable methods.
- The installation of this product must include a solids interceptor, vent and running trap located up stream and as close to the source as possible and a vent located within the distance specified in Table 82.31-1, Wis. Adm. Code, on the downstream side of the product.
- Sizing of this product must be in accordance with Jay R. Smith Remediator sizing procedures specified on their published document # PM 1040.

This approval supersedes the approval issued on INSERT DATE under product file number #####.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number #####.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

JAY R.SMITH MFG.

Page 2

February 10, 2005

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov